Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 06-04969
Inspection Number: 02687291

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 976 COUNTRY CLUB PKWY CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/23/2007
Inspection Time: 7:52 AM
Inspection Type: Exterior Sheathing
Inspection Code: 57
Outcome: Cancelled
Inspected By: Rich Garrett
Charge Reinspection Fee: No