



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 25-07616  
Inspection Number: 04004649

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

**Job Address:** 32 ALBION PL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Addition

### Inspection Details

**Inspection Date:** 12/11/2025  
**Inspection Time:** 8:32 AM  
**Inspection Type:** Insulation Thermal  
**Inspection Code:** 36  
**Outcome:** Disapproved  
**Inspected By:** Clayton Rodeback  
**Charge Reinspection Fee:** No

### Comments

Partial. Ok to cover basement lid at game room.