



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 06-06274

Inspection Number: 02693765

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 8345 RAPHAEL LN LITTLETON

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 04/03/2007

Inspection Time: 12:00 AM

Inspection Type: Underground Plumbing

Inspection Code: 12

Outcome: Approved

Inspected By: Brian Brown

Charge Reinspection Fee: No