



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-07616
Inspection Number: 04005600

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 32 ALBION PL CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 12/17/2025
Inspection Time: 10:30 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

1. Exhaust fan missing at master bathroom toilet area
2. Closet lighting in master suite incomplete
3. Smoke/ CO detector wiring missing
4. UFER connection incomplete-located in master bedroom addition SE corner