



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-07616
Inspection Number: 04006245

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 32 ALBION PL CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 12/22/2025
Inspection Time: 1:36 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Nathan Waldschmidt
Charge Reinspection Fee: No

Comments

1. Smoke/ CO detector wiring still missing.
 2. UFER connection incomplete-located in master bedroom addition SE corner. 250.50. (Ground rods installed)
- Notes:
3. Chandelier not permitted in master closet. 410.16(C) (ceiling fan rated box installed)
 4. Chandelier not permitted above bathtub. 410.10(D) (ceiling fan rated box installed)