



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-07616
Inspection Number: 04006251

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 32 ALBION PL CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 12/22/2025
Inspection Time: 10:20 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Anthony Frank
Charge Reinspection Fee: No