



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676  
Inspection Number: 04007131

## Building Inspection Report

Code Reviewed Under: 2021 IBC

### Permit Information

**Job Address:** 7979 BUTTE CREEK ST LITTLETON  
**Job Type:** Building  
**Description:** CM - Commercial  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 01/02/2026  
**Inspection Time:** 11:19 AM  
**Inspection Type:** Foundation Insulation  
**Inspection Code:** 114  
**Outcome:** Approved  
**Inspected By:** Duke Thompson  
**Charge Reinspection Fee:** No

### Comments

Foundation insulation, partially backfilled around entire foundation, third-party letters needed by final