



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-07616
Inspection Number: 04013306

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 32 ALBION PL CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 02/19/2026
Inspection Time: 1:27 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Nathan Waldschmidt
Charge Reinspection Fee: No

Comments

1. Kitchen fridge shall be AFCI/GFCI protected.
2. Future island circuit AFCI/GFCI protected.
3. Range circuit/plug shall be GFCI protected.