



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04018494

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 03/31/2026
Inspection Time: 1:41 PM
Inspection Type: Exterior Wall Sheathing Partial
Inspection Code: 105
Outcome: Approved
Inspected By: Dusty Welz
Charge Reinspection Fee: No

Comments

1. Approved for North facing elevations except lower-north kitchen wall, east elevation of gym and south elevation of gym to grid line 13.
2. Missing seam blocking on north kitchen elevation and opening strapping.
3. See blue highlighter on separated sheet S2.01.