



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04019029

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/02/2026
Inspection Time: 1:09 PM
Inspection Type: Rough HVAC Partial
Inspection Code: 25
Outcome: Approved
Inspected By: Dusty Welz
Charge Reinspection Fee: No

Comments

Supply and return Hard duct on first floor for classrooms, bathrooms, corridor, conference room and back of house rooms as highlighted green on M1.01A. HVAC Insulation and ceiling closure inspections required when ready.