



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04019612

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/08/2026
Inspection Time: 3:43 PM
Inspection Type: Floor Truss
Inspection Code: 135
Outcome: Disapproved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

- 1.R116 ,R102 missing clips north and south, C16 strapping on plate breaks.
2. Missing H25, A35, both sides.
3. Rooms 202,204,206 missing lateral blocking.
4. B1d floor trusses appear to be in the wrong location, should it be on top of a shear wall.