



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04019732

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/08/2026
Inspection Time: 3:39 PM
Inspection Type: Roof Truss Partial
Inspection Code: 128
Outcome: Disapproved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

1. Provide RFI for repairs on vertical webbing stair well 1 roof trusses. Engineered repair letter.
2. Reference sheet S5.05 detail 10 and sheet S5.20 detail attachments.
3. Reference MYTECH INSTRUCTIONS and bracing is missing throughout.
4. SW foyer trusses are not completed.
5. Corridors ledger attachments details are lacking.