



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04020116

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/10/2026
Inspection Time: 3:31 PM
Inspection Type: Rough Frame Partial
Inspection Code: 26
Outcome: Approved
Inspected By: Duke Thompson
Charge Reinspection Fee: No

Comments

1. Second floor, interior shear walls screw pattern, complete at upper portion
2. Tighten screws installed bottom plate, main floor, corridor room 1 02, 114, 115, 116