



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04020442

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/14/2026
Inspection Time: 1:02 PM
Inspection Type: Drywall Partial
Inspection Code: 37
Outcome: Disapproved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

The restrooms are required to have from the wet wall, left side and right side 5 foot den shield in lieu of half-inch type X sheet rock.
Rooms 103, 104, 105, 106, 107, 108, 110, 111, 112, 113, 114, 115 and 160 are OK to proceed. Please check screw patterns per plan detail as requested.. please show corrections on the next inspection.