



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04020446

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 04/14/2026
Inspection Time: 1:02 PM
Inspection Type: Rough Frame Partial
Inspection Code: 26
Outcome: Disapproved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

The corridor to include rooms 202, 203, 204, 205, 206, 207, 209, 214, 215, 216, 217, 218, 219. OK.
All holddowns must be completed as with fire, stopping for all MEP penetrations. Not OK.
Stairwell number one is required to have tempered glass right hand side not OK
Room 218 door swing must have tempered glass., Within 24 inches. Not OK.
Please correct as required and recall for inspection.