



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 06-04969
Inspection Number: 02709424

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 976 COUNTRY CLUB PKWY CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/29/2007
Inspection Time: 12:00 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Wayne Elmore
Charge Reinspection Fee: No