



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 26-02665
Inspection Number: 04022452

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4431 VALLEYBROOK DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/30/2026
Inspection Time: 12:14 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Jonathan Pastore
Charge Reinspection Fee: No

Comments

electrical contractor workman's comp expired
Kitchen remodel new lighting and updating existing lighting, no more than 4 openings per small appliance circuit, existing range receptacle to be boxed and blanked off. AFCI and GFCI protection required where applicable, will check @ final and new lighting added to powder bath.