



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 26-02870
Inspection Number: 04023471

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 661 RUBY TRUST DR CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/11/2026
Inspection Time: 1:34 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

Basement bar area and fireplace OK