



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-03042
Inspection Number: 02712554

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 5132 PINE RIVER TRL CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 07/19/2007
Inspection Time: 12:00 AM
Inspection Type: Construction Meter
Inspection Code: 10
Meter Release: Yes
Provider: IREA
Outcome: Approved
Inspected By: Wayne Elmore
Charge Reinspection Fee: No