



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 26-02082  
Inspection Number: 04025139

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

**Job Address:** 2050 FOX FIRE ST HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 05/21/2026  
**Inspection Time:** 11:46 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

1)light at bottom of stairs inoperable  
2)protect horizontal NM unfinished mech room walls  
Correct and proceed