



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 26-00248
Inspection Number: 04025306

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 6505 PINERY CENTER BLVD PARKER
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 05/26/2026
Inspection Time: 11:30 AM
Inspection Type: Foundation Insulation
Inspection Code: 114
Outcome: Disapproved
Inspected By: Dusty Welz
Charge Reinspection Fee: No

Comments

Sheet SP.1.0 pink highlighter. Foundation insulation has been approved on south, west and north elevations. Left open until least wall is complete. Please have a copy of the county approved structural drawings on site. Today is a partial approval for the north facing elevation only. Please only schedule partials until completed.