



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 26-00248
Inspection Number: 04026014

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 6505 PINERY CENTER BLVD PARKER
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 05/29/2026
Inspection Time: 12:29 PM
Inspection Type: Slab Electrical Partial
Inspection Code: 74
Outcome: Approved
Inspected By: Nathan Waldschmidt
Charge Reinspection Fee: No

Comments

- (2) 4" from main disconnect to inside MDP
- (3) 3/4", (2) 1" from electrical room stubbed outside.
- (2) 3" from phone closet stubbed outside.