



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 26-04542
Inspection Number: 04027259

Building Inspection Report

Permit Information

Job Address: 2146 CASTLE RIDGE WAY HIGHLANDS RANCH
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 06/09/2026
Inspection Time: 11:31 AM
Inspection Type: Rough HVAC
Inspection Code: 27
Outcome: Disapproved
Inspected By: Nathan Waldschmidt
Charge Reinspection Fee: No

Comments

1. Manual J,D and S need to be submitted to Douglas County for the new units being installed.
Recall inspection once approved by planning.