Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-02945
Inspection Number: 02716169

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 5131 PINE RIVER TRL CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 08/09/2007
Inspection Time: 12:00 AM
Inspection Type: Structural Floor
Inspection Code: 14
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No