



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 07-02945  
Inspection Number: 02722745

## Building Inspection Report

Code Reviewed Under: 2003 IRC

### Permit Information

Job Address: 5131 PINE RIVER TRL CASTLE ROCK  
Job Type: Building  
Description: RS - Stock  
Scope of Work: New

### Inspection Details

Inspection Date: 09/17/2007  
Inspection Time: 12:00 AM  
Inspection Type: Exterior Sheathing  
Inspection Code: 57  
Outcome: Approved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No