Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-02945
Inspection Number: 02729594

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 5131 PINE RIVER TRL CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 10/19/2007
Inspection Time: 8:29 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Cancelled
Inspected By: Wayne Elmore
Charge Reinspection Fee: No