



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 07-04931  
Inspection Number: 02729624

## Building Inspection Report

### **Permit Information**

**Job Address:** 2577 BUTTE CIR SEDALIA  
**Job Type:** Roofing  
**Description:** Tile/Slate -

### **Inspection Details**

**Inspection Date:** 10/19/2007  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Midroof  
**Inspection Code:** 60  
**Outcome:** Approved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No