



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04033953

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 07/28/2026
Inspection Time: 10:55 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

1. Submit all third-party letters, upload to E plans. provide all necessary, inspection, sign, offs, i.e. health department, fire department, electrical department, plumbing department.
2. Install paddle handles and all gang bathrooms, thumb twist are not acceptable.
3. Per sheet A1.02 the right side swing is incorrect for the E grass exit gate, plans reference two leafs. The directional swing is incorrect.
4. Per sheet A1.02, Keynote number eight the safe dispersal area signage is incorrect, reverse north and south. SIGNAGE.
5. USE THE CORRECT AGENCY FOR ALL ELEVATOR INSPECTIONS.