



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 07-05403
Inspection Number: 02736728

Building Inspection Report

Permit Information

Job Address: 3594 COTTONWOOD AVE PARKER
Job Type: Roofing
Description: Composition -

Inspection Details

Inspection Date: 12/03/2007
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No