



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 25-06676
Inspection Number: 04035739

Building Inspection Report

Code Reviewed Under: 2021 IBC

Permit Information

Job Address: 7979 BUTTE CREEK ST LITTLETON
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 08/06/2026
Inspection Time: 1:05 PM
Inspection Type: Final Plumbing
Inspection Code: 40
Outcome: Approved
Inspected By: Tim Pendleton
Charge Reinspection Fee: No

Comments

Inspection completed by the State of Colorado (DORA)