



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 07-04109
Inspection Number: 02741296

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 5280 RED PASS LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 01/08/2008
Inspection Time: 12:00 AM
Inspection Type: Drip Edge
Inspection Code: 58
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No