



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 07-06003
Inspection Number: 02741972

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 9317 CORNELL CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/14/2008
Inspection Time: 12:00 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: Ben Robinson
Charge Reinspection Fee: No