



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-06003
Inspection Number: 02741973

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 9317 CORNELL CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/10/2008
Inspection Time: 3:53 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Cancelled
Inspected By: Dave Ransom
Charge Reinspection Fee: No

Comments

already passed