Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-04109
Inspection Number: 02742409

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 5280 RED PASS LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 01/15/2008
Inspection Time: 12:00 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release: Yes
Provider: Black Hills Energy
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No