



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 07-06003  
Inspection Number: 02744370

## Building Inspection Report

Code Reviewed Under: 2003 IRC

### Permit Information

**Job Address:** 9317 CORNELL CIR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 01/29/2008  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** David Lewis  
**Charge Reinspection Fee:** No

### Comments

bsmt partial