



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 07-03740
Inspection Number: 02748102

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 1075 COUNTRY CLUB ESTATES DR CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/26/2008
Inspection Time: 8:27 AM
Inspection Type: Ufer Ground Electrode
Inspection Code: 66
Outcome: Approved
Inspected By: Rick Sugar
Charge Reinspection Fee: No