DOUGLAS COUNTY
BUILDING DIVISION COLORADO

Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 07-03765
Inspection Number: 02748470

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 1 EAGLE POINTE LN CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/29/2008
Inspection Time: 12:00 AM
Inspection Type: Drip Edge
Inspection Code: 58
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No