



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 07-02945  
Inspection Number: 02748554

## Building Inspection Report

Code Reviewed Under: 2003 IRC

### Permit Information

**Job Address:** 5131 PINE RIVER TRL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Stock  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 02/29/2008  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Frame  
**Inspection Code:** 41  
**Outcome:** Approved  
**Inspected By:** Rich Garrett  
**Charge Reinspection Fee:** No