



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 08-00855
Inspection Number: 02751215

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 9317 CORNELL CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/21/2008
Inspection Time: 12:38 PM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Cancelled
Inspected By: Rich Garrett
Charge Reinspection Fee: No

Comments

n/a