



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 07-03765
Inspection Number: 02751540

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 1 EAGLE POINTE LN CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/26/2008
Inspection Time: 7:27 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Cancelled
Inspected By: Wayne Elmore
Charge Reinspection Fee: No