



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 06-06350
Inspection Number: 02778109

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 1 ELK POINTE LN CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 09/29/2008
Inspection Time: 12:00 AM
Inspection Type: Pool Bonding Partial
Inspection Code: 59
Outcome: Approved
Inspected By: Rich Edgett
Charge Reinspection Fee: No