



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 08-03739
Inspection Number: 02800444

Building Inspection Report

Code Reviewed Under: 2003 IRC

Permit Information

Job Address: 10184 BENTWOOD CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/27/2009
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Jerry Wlodarek
Charge Reinspection Fee: No