



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 09-01676  
Inspection Number: 02804307

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 731 MUELLER DR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Addition

### Inspection Details

**Inspection Date:** 07/13/2009  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Disapproved  
**Inspected By:** Rick Chadwick  
**Charge Reinspection Fee:** No

### Comments

RES 3