



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 09-03380  
Inspection Number: 02809143

## Building Inspection Report

### Permit Information

**Job Address:** 7774 JARED WAY LITTLETON  
**Job Type:** Roofing  
**Description:** Composition -

### Inspection Details

**Inspection Date:** 08/31/2009  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Roofing  
**Inspection Code:** 34  
**Outcome:** Approved  
**Inspected By:** Brian Brown  
**Charge Reinspection Fee:** No