Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 10-00855
Inspection Number: 02830917

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 2276 BITTERROOT PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/06/2010
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Courtney Arford
Charge Reinspection Fee: No