



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 10-00855  
Inspection Number: 02831273

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 2276 BITTERROOT PL HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 04/09/2010  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Drywall  
**Inspection Code:** 38  
**Outcome:** Approved  
**Inspected By:** Brian Brown  
**Charge Reinspection Fee:** No