



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 10-02133
Inspection Number: 02840377

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 6278 OXFORD PEAK PL CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/29/2010
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No