



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 10-02352  
Inspection Number: 02840603

## Building Inspection Report

Code Reviewed Under: 2006 IBC

### Permit Information

**Job Address:** 14347 S EAST CHERRY CREEK RD LARKSPUR  
**Job Type:** Building  
**Description:** AU - Barn  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 06/30/2010  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Ufer Ground Electrode  
**Inspection Code:** 66  
**Outcome:** Approved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

Bonding to steel mesh under slab @ south door