



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 10-02352  
Inspection Number: 02843782

## Building Inspection Report

Code Reviewed Under: 2006 IBC

### Permit Information

**Job Address:** 14347 S EAST CHERRY CREEK RD LARKSPUR  
**Job Type:** Building  
**Description:** AU - Barn  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/27/2010  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Plumbing  
**Inspection Code:** 28  
**Outcome:** Approved  
**Inspected By:** Rich Garrett  
**Charge Reinspection Fee:** No