



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 10-02352
Inspection Number: 02844190

Building Inspection Report

Code Reviewed Under: 2006 IBC

Permit Information

Job Address: 14347 S EAST CHERRY CREEK RD LARKSPUR
Job Type: Building
Description: AU - Barn
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/29/2010
Inspection Time: 12:00 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No